
INSPECTION REPORT

Fire Extinguisher Monthly Inspection

TYPE	SITE	STARTED	COMPLETED
Monthly Inspection	Bangkok Head Office	03 Nov 2026, 09:00	03 Nov 2026, 09:40



2 checkpoints need action

82% PASS score | 12 of 12 inspected

TOTAL	PASS	FAIL	N/A
12	9	2	1

ACTION REQUIRED (2)

Floor 2 | FE-2-02 · Fire extinguisher, stair B — HIGH
Finding: Gauge needle in the red zone. Replace the extinguisher.
No comparable result in the previous report

Floor 3 | FE-3-01 · Fire extinguisher, lift lobby — MEDIUM
Finding: Seal broken, safety pin loose.
No comparable result in the previous report

SUPERVISOR COMMENTS

Replace FE-2-02 and reseal FE-3-01 by Friday.

RESULT BY FLOOR

3	50% (2/4)	2	75% (3/4)
1	100% (4/4)		

RESULT BY TYPE

TYPE	TOTAL	PASS	FAIL	N/A	PASS %
CO2 Capacity: 5 lb: 6 Registered quantity: 6	6	5	1	0	83%
DP Capacity: 15 lb: 6 Registered quantity: 6	6	4	1	1	67%

NOT APPLICABLE (1)

Floor 3 | FE-3-04 · Fire extinguisher, plant room - Room closed for renovation.

CHECKLIST DETAILS (12 checkpoints)

FLOOR 3 — **2/4 PASS (50%)**

#	CHECKPOINT / LOCATION / INSPECTION DETAILS	RESULT	CHECKED
1	**FE-3-01 · Fire extinguisher, lift lobby** Floor 3, lift lobby Finding: Seal broken, safety pin loose. Pressure gauge: PASS Safety pin & seal: FAIL	FAIL	03 Nov 09:27
2	**FE-3-02 · Fire extinguisher, stair B** Floor 3, stair B Pressure gauge: PASS Safety pin & seal: PASS Hose & nozzle: PASS	PASS	03 Nov 09:30
3	**FE-3-03 · Fire extinguisher, east corridor** Floor 3, east corridor Pressure gauge: PASS Safety pin & seal: PASS Hose & nozzle: PASS	PASS	03 Nov 09:33
4	**FE-3-04 · Fire extinguisher, plant room** Floor 3, plant room Room closed for renovation.	N/A	03 Nov 09:36

FLOOR 2 — **3/4 PASS (75%)**

#	CHECKPOINT / LOCATION / INSPECTION DETAILS	RESULT	CHECKED
5	**FE-2-01 · Fire extinguisher, lift lobby** Floor 2, lift lobby Pressure gauge: PASS Safety pin & seal: PASS Hose & nozzle: PASS	PASS	03 Nov 09:15
6	**FE-2-02 · Fire extinguisher, stair B** Floor 2, stair B Finding: Gauge needle in the red zone. Replace the extinguisher. Pressure gauge: FAIL Safety pin & seal: PASS	FAIL	03 Nov 09:18
7	**FE-2-03 · Fire extinguisher, east corridor** Floor 2, east corridor Pressure gauge: PASS Safety pin & seal: PASS Hose & nozzle: PASS	PASS	03 Nov 09:21
8	**FE-2-04 · Fire extinguisher, plant room** Floor 2, plant room Pressure gauge: PASS Safety pin & seal: PASS Hose & nozzle: PASS	PASS	03 Nov 09:24

FLOOR 1			4/4 PASS (100%)
#	**CHECKPOINT / LOCATION / INSPECTION DETAILS**	**RESULT**	**CHECKED**
9	**FE-1-01 · Fire extinguisher, lift lobby** Floor 1, lift lobby Pressure gauge: PASS Safety pin & seal: PASS Hose & nozzle: PASS	PASS	03 Nov 09:03
10	**FE-1-02 · Fire extinguisher, stair B** Floor 1, stair B Pressure gauge: PASS Safety pin & seal: PASS Hose & nozzle: PASS	PASS	03 Nov 09:06
11	**FE-1-03 · Fire extinguisher, east corridor** Floor 1, east corridor Pressure gauge: PASS Safety pin & seal: PASS Hose & nozzle: PASS	PASS	03 Nov 09:09
12	**FE-1-04 · Fire extinguisher, plant room** Floor 1, plant room Pressure gauge: PASS Safety pin & seal: PASS Hose & nozzle: PASS	PASS	03 Nov 09:12

SIGN-OFF

INSPECTED BY



Somchai Srisuk
Safety Officer · ID: somchai.s
Signed 03 Nov 2026, 09:40 (Bangkok)

VERIFIED BY



Anan K.
Facilities Manager
Signed 03 Nov 2026, 09:44 (Bangkok)